

Article

Modelling and Control of a Grid-Connected RES-Hydrogen Hybrid Microgrid

Jonny Esteban Villa Londono ¹, Andrea Mazza ^{1,2,*} , Enrico Pons ^{1,2} , Harm Lok ³ and Ettore Bompard ^{1,2}

¹ **Dipartimento** Energia “Galileo Ferraris”, Politecnico di Torino, Corso Duca degli Abruzzi 24, 10129 Torino, Italy; jonny.esteban.villa@gmail.com (J.E.V.L.); enrico.pons@polito.it (E.P.); etttore.bompard@polito.it (E.B.)

² Energy Center Lab (EC-L), Politecnico di Torino, via Paolo Borsellino 38/16, 10138 Torino, Italy

³ **Centre of Expertise Energie**, Hanze University of Applied Sciences, Zernikelaan 17, 9747 AA, Groningen, The Netherlands; h.lok@pl.hanze.nl

* Correspondence: andrea.mazza@polito.it;

Abstract: This paper proposes a Hybrid Microgrid (H μ G) model including distributed generation (DG) and a hydrogen-based storage system, controlled through a tailored control strategy. The H μ G is composed of three DG units, two of them supplied by solar and wind sources, and the latter one based on the exploitation of the Proton Exchange Membrane (PEM) technology. Furthermore, the system includes an alkaline electrolyser, which is used as a responsive load to balance the excess of Variable Renewable Energy Sources (VRES) production, and to produce the hydrogen that will be stored into the hydrogen tank and that will be used to supply the fuel cell in case of lack of generation. The main objectives of this work are to present a validated dynamic model for every component of the H μ G and to provide a strategy to reduce as much as possible the power absorption from the grid by exploiting the VRES production. The alkaline electrolyser and PEM fuel cell models are validated through real measurements. The State of Charge (SoC) of the hydrogen tank is adjusted through an adaptive scheme. Furthermore, the designed supervisor power control allows reducing the power exchange and improving the system stability. Finally, a case, considering a summer load profile measured in an electrical substation of *Politecnico di Torino*, is presented. The results demonstrate the advantages of a hydrogen-based micro-grid, where the hydrogen is used as medium to store the energy produced by photovoltaic and wind systems, with the aim to improve the self-sufficiency of the system.

Keywords: Hybrid microgrid; Hydrogen storage system; Alkaline electrolyser; PEM fuel cell; Low-Carbon Future Energy Systems; Variable Renewable Energy Sources



Citation: Villa Londono, J.E.; Mazza, A.; Pons, E.; Lok, H.; Bompard, E. Modelling and Control of a Grid-Connected RES-Hydrogen Hybrid Microgrid. *Energies* **2021**, *1*, 0. <https://doi.org/>

Academic Editor:

Received: 31 December 2020

Accepted: 4 March 2021

Published:

Publisher's Note: MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



Copyright: © 2021 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

During the last years, the number of research and development projects considering as main energy sources the so called Variable Renewable Energy Sources (VRES), such as photovoltaic (PV) and wind (WD), increased. These projects are largely driven by government regulations. Thus, the increase of RES challenged scientists and technicians to study and implement new strategies to improve the operation and stability of energy systems, and, in the meanwhile, to decrease the dependency by fossil fuels or, under a different point of view, lessening the emission of greenhouse gases [1]. However, the intermittency typical of VRES introduces an additional risk which could compromise the successful satisfaction of the load [2]. Therefore, the electrical system needs *flexibility*, that can be provided in different ways. In [3], the flexibility is guaranteed by coordinating several Peltier Effect refrigerator [4]. In [5] the flexibility is provided by a compression-based refrigerator, whereas in [6] the exploitation of distributed multi-energy system is suggested as form of flexibility for the electrical grid. In this context, Power-to-X (P2X) technologies, such as Power-to-Gas (P2G), Power-to-Fuels (P2F), and Power-to-Heat (P2H), are gaining a leading role for providing flexibility to the electricity grid, because (i) they are able to

exploit the existing infrastructure (such as the gas network and district heating) and (ii) allow decarbonising other sectors using the produced commodities (i.e., gas, liquids and heat) starting from an excess of VRES [7]. Two of the above mentioned processes (i.e., P2G and P2F) are based on the production of *green hydrogen* that can be successively converted in methane or liquid fuels by combining it with CO₂. However, this cannot determine the solution of the CO₂ emission. The only way is to use as energy carrier the green hydrogen and make use of it as basic element for the future energy system: this perspective, even though was indicated as possible and desirable in the past (see for example [8]), is now is gaining a momentum. In particular, on the basis of the European Green Deal [9], the European Commission presented the EU Hydrogen Strategy [10], which includes two phases, having as objective to reach 6 GW of installed electrolyzers up to the end of 2024 (with a production of up to 1 million tonnes of green hydrogen) and successively jump up to 40 GW at the end of 2030, with a production reaching 10 millions tonnes, to be compliant with the goal of covering around 14% of the European energy mix with green hydrogen [11]. In China, the definition of the different types of hydrogen has been debated and a recent standard reports their characteristics, by defining low-carbon hydrogen, clean hydrogen and renewable hydrogen on the basis on their specific emission and the origin of the electricity [12].

Several hydrogen-based energy projects around the world aimed or are aiming to study how to properly exploit the advantages from the coupling of RES-based power plants and hydrogen: taking as example the European Union, the activities in this topic are led by the *Fuel Cells and Hydrogen Joint Undertaking (FCH JU)* and, since its foundation in 2008, more than 220 projects have been propitiated [13]. This great interest is also due to the possibility to have a bi-directional conversion, i.e., from electricity to hydrogen (through electrolyzers) and viceversa (by using fuel cells): this opens perspectives in which the hydrogen, properly stored, may be used as an *energy buffer* that, combined with electrolyzers and fuel cells, could improve the self sufficiency of the prosumers, by reducing the grid dependency. With this scope, the hydrogen-based system is used as an Energy Storage System (ESS) and the prosumer plant can be seen as a Hybrid Micro-Grid (HμG).

A HμG may combine RES power plants, gas-based devices and energy storage capability. It can supply remote customers with clean and cost-effective electricity [14]: in fact, if properly designed, HμGs can be operated also in islanded way [15]. The structure to consider could be composed by a whole H₂ energy system, which employs mainly fuel cells, electrolyzers and hydrogen tanks. Therefore, to present these new hybrid systems as a potential solution, two main aspects have to be considered: (i) novel algorithms to manage the surplus of energy associated with RES, and (ii) new strategies of energy management, in order to drive the power flow calculation of hydrogen systems integrated into the HμGs [1].

In literature, the contributions on this topic focus on specific aspects of the system. For example, in [16], the author proposed the sizing of a hybrid plants (including photovoltaic and fuel cells) based on models included in the software HOMER. In [17], the authors evaluated the sizing of batteries and hydrogen energy storage for a real domestic load, but with infinite storage capacity. In [18] different meta-heuristic methods have been compared to optimally design an isolated HμG. All the above contributions consider simulation time steps of one hour, which are good enough for energy evaluation, but cannot properly represent the dynamics. In [19], the time step is shorter (around 30 s), but the measurements of the electrical load were not based on real data and the response of electrolyzers and fuel cells are based on simplified models. In [20], the authors proposed a model implemented on a real-time simulation, by considering a DC grid layout. Also in this case, a simplified response of the electrolyser and fuel cell is considered. Even though considering dynamic behaviour of the components, other contributions investigate specific aspects with small size components. For example, the authors in [21] presented a HμG including an electrolyser and a fuel cell of size around 1kW. The same layout has been employed in [22] to investigate the use of Model Predictive Control in the energy management of the HμG.

In this paper, a H μ G layout based on validated models of all the components is proposed. The implemented control strategy aims to reduce as much as possible the dependence from the main grid, to improve the self-sufficiency of the prosumer. The main contributions of the paper are: (i) the hydrogen-based components, whose sizes are higher than the ones previously considered for fast dynamic studies (8 kW for the electrolyser and 12.5 kW for the fuel cells), (ii) the use of a high-speed sampled real electrical load, which has been measured at Politecnico di Torino (Italy) and (iii) the validation of all the components of the system, based on real data. In particular, the validation data for the PEM fuel cell have been collected locally, whereas the validation data of the electrolyser operation have been collected remotely as in Reference [23] with high sampling frequency.

The paper is organized as follows: Section 2 introduces the layout of the H μ G and the dynamic models of the components i.e., PV and WD generation systems, electrolyser, fuel cell and hydrogen tank. Section 3 shows the implemented control strategy, whereas Section 4 presents the simulation results with different case studies. Finally, the last section lists the concluding remarks.

2. H μ G Modelling

2.1. H μ G Layout

The H μ G presented in this paper is composed of multiple generation sources, an EES, and a non-flexible load. The generation system is composed of a PV system, a WD generator and a Proton Exchange Membrane (PEM) fuel cell (FC). The ESS consists basically in a hydrogen storage tank (HST) coupled with an alkaline electrolyser (ELY). The ESS subsystem is connected to the non-flexible load and has enough capacity to supply the FC when needed.

A general model of hydrogen storage system is integrated to manage the production and consumption of energy from the electrolyser and the PEM FC respectively. The electrolyser is used to absorb rapidly the output power from RES and generates hydrogen as fuel for FCs [24,25].

The schematic diagram of the H μ G is presented in Figure 1. The sum of the demand and electrolyser power is equal to the sum of the grid contribution and the output power generated by WD and PV generators and PEM fuel cells.




Figure 1. Schematic diagram of H μ G.

Equation (1) represents the power balance in the H μ G:

$$P_{LOAD} = P_{GRID} + P_{WD} + P_{PV} + P_{FC} - P_{ELY} \quad (1)$$

where P_{LOAD} is the power demand, P_{GRID} is the power provided by the grid, P_{WD} and P_{PV} are the RES contributions, from the wind system and from the solar system respectively, P_{FC} is the power produced by the PEM fuel cell and P_{ELY} the power consumed by the electrolyser.

In the following sections, a general description of the technical specifications for each component is presented. Furthermore, the models used to simulate each component are described, together with their testing and validation. All the components' models and the overall H μ G system are simulated in Matlab Simulink®.

2.2. Load Demand

The load is considered to absorb only active power. The load profiles are loaded from a file. Two load profiles are considered in this work: (a) a synthetic load profile built with the aim to test the proper system operation and (b) a real load profile, obtained from real measurements.

The measurements were performed in a Medium Voltage (MV)/Low Voltage (LV) substation on a LV feeder supplying a data center at Politecnico di Torino on 18th and 19th June 2019. We used a high speed recorder Hioki 8880/20 MR with a direct connection to the feeder for voltage measurements and probes pico technology TA 167 for current measurements. The sampling time was set to 1 s.

The two load profiles are presented in Figure 2.




Figure 2. Load demand with active power in kW. (a) validation profile and (b) static load.

2.3. Wind Turbine System

One of the renewable generators of the H μ G is the wind turbine system. The turbine considered in the H μ G has a rated power of 15 kW, a rated speed of 15 m/s, a cut-in speed of 5 m/s and a cut-out speed of 30 m/s. The average daily electrical production is about 8 kWh.

2.4. PV System

The second renewable generator of the H μ G is the PV system; it delivers a maximum of 23 kW at 1000 W/m² sun irradiance. The technical specifications of the PV system are summarized in Table 1.

Table 1. Technical specifications of the PV system.

Technical Parameter	Value	Unit
Array rated power	23	kW
Cells per module	60	-
Module Open Circuit voltage	36.3	V
Module Short Circuit current	7.8	A
Series strings	4	-
Parallel strings	27	-
Voltage at Maximum Power Point (MPP) per module	29	V
Current at MPP per module	7.35	A
Maximun power per module at MPP	213.15	W
Maximun power per array at MPP	23.02	kW

2.5. Alkaline Electrolyser

Electrolysers produce hydrogen from water dissociation. For the H μ G described in this work, we modelled an alkaline electrolyser which, bytheway, it the most mature and available in the market [26].

In an alkaline electrolyser, the alkaline solution (usually based on KOH at 30% in weight) is used as electrolyte. The modelled electrolyser has rate power 8 kW and rate hydrogen flow equal to 1.255 Nm³/h, with pressure 12 barg and purity higher than 99.3%. The electrolyser comprises one stack of 8 kW, composed of 5 series-connected cells. The average efficiency is about 54.4 % (low heating value). The electrolyser technical specifications are presented in Table 2.

Table 2. Technical specifications of the alkaline electrolyser.

Technical Parameter	Value	Unit
Nominal voltage	45	V
Nominal current	130	A
Minimum Power	2	kW
Outlet pressure	12	barg
H ₂ rate flow	1.255	Nm ³ /h
Electrolyte	KOH 30	%
Operation temperature	31	°C
Cell number	5	-
Electrode area	0.15	m ²

The alkaline electrolyser model presented is related to an Advanced Alkaline electrolyser. In the electro-chemical model temperature and pressure depends on Faraday efficiency, whereas the temperature depends on current-voltage relation [27,28].

The model may forecast the cell voltage, the hydrogen production, Faraday efficiency and the electrolyser operating temperature [27]. In Figure 3 the block diagram of the sub-models is presented. The sub-models are described in detail in the next paragraphs.




Figure 3. Block diagram of sub-models for an advanced alkaline electrolyser.

2.5.1. Thermodynamic Sub-Model

The reversible voltage is defined as the minimum voltage that, applied to the water molecule, allows its separation. The reversible voltage U_{rev} is expressed in terms of the Gibbs Energy variation, as reported in Equation (2).

$$\Delta G = \Delta H - T \cdot \Delta S \quad (2)$$

The Gibbs energy can be associated with reversible voltage and the neutral cell voltage as shown in Equation (3).

$$U_{rev} = \frac{\Delta G}{z \cdot F} \quad (3)$$

where the reversible voltage U_{rev} is measured in V and is sensible to reaction temperature and pressure, z the hydrogen molecule electrons, and F is the Faraday constant, equal to $F = 96485.3329$ C/mol. The total energy demand ΔH refers to thermo-neutral cell voltage and it is expressed by Equation (4).

$$U_{th} = \frac{\Delta H}{z \cdot F} \quad (4)$$

2.5.2. Electrical Sub-Model

The electrical sub-model allows the estimation of the voltage-current relationship. The model inputs are the electrical power and the stack temperature, whereas the output is the voltage-current couple for every stack cell at different temperatures [29].

The relationship of the electrical power on the electrolyser is given Equation (5):

$$W_{ELY} = N_{LEY} \cdot I_{ELY} \cdot U_{ELY} \quad (5)$$

where W_{ELY} is the consumed power in W, N_{ELY} is the of stack cell number, I_{ELY} is the stack current of the electrolyser in A, U_{ELY} and is the electrolyser cell voltage in V.

In Equation (5), the electrolyser cell voltage U_{ELY} represents an empirical $I - U$ model for electrolysers. The kinetics of the cell electrode are modeled with the $I - U$ curve, which includes the ohmic and stack temperature effects. The $I - U$ curve can be expressed by the sum of three terms, as reported in Equation (6): the reversible voltage U_{rev} , the activation voltage U_a , and the ohmic overvoltage U_{ohm} . All the terms are expressed in V [30].

$$U_{ELY} = U_{rev} + U_a + U_{ohm} \quad (6)$$

The first term of the right-side of Equation (6) represents the minimum voltage required to activate the ideal electrolyser cell, as expressed above in Equation (3). The second and third terms refer to the activation and ohmic overvoltages that can be defined as in Equations (7) and (8), respectively.

$$U_a = \sigma \cdot \log \left(\frac{\tau}{A_{ELY}} \cdot I_{ELY} + 1 \right) \quad (7)$$

$$U_{ohm} = \frac{r}{A_{ELY}} \cdot I_{ELY} \quad (8)$$

where σ and τ are empirical coefficients referring to the electrodes' overvoltages, r represents the electrolyte ohmic effect Ωm^2 and A_{ELY} is the electrolyser stack area in m^2 .

2.5.3. Hydrogen Production Sub-Model

The hydrogen production is directly proportional to the current in the external circuit (i.e., transfer rate of electrons to electrodes):

$$m_{H_2} = \eta_F \cdot \frac{N_{ELY} \cdot I_{ELY}}{z \cdot F} \quad (9)$$

where m_{H_2} is the hydrogen flow rate in mol/s, η_F is the Faraday efficiency, and I_{ELY} is the stack current in A.

2.5.4. Faraday Efficiency Sub-Model

The Faraday efficiency represents the losses caused by parasitic currents: their value is inversely proportional to the current density, i.e., they increase if the current density decreases. Moreover, the value of the parasitic currents increases with a temperature rise, which lowers the Faraday efficiency, as shown in Equation (10):

$$\eta_F(\rho, T) = f_2(T_{ELY}) \cdot \frac{\rho^2}{\rho^2 + f_1(T_{ELY})} \quad (10)$$

where f_1 and f_2 are empirical constants taken from [31], and ρ is the current density expressed by Equation (11):

$$\rho = \frac{I_{ELY}}{A_{ELY}} \quad (11)$$

2.5.5. Thermal Sub-Model

The thermal behavior of the electrolyser cannot be neglected in case of connection to RES. In fact, the temperature variation impacts the hydrogen production over the time. The temperature of the electrolyte can be determined by solving the thermal energy balance in Equation (12):

$$C_{th,ELY} \frac{dT_{ELY}}{dt} = \dot{Q}_{ELY}^{(G)} - \dot{Q}_{ELY}^{(C)} - \dot{Q}_{ELY}^{(L)} \quad (12)$$

where $C_{th,ELY}$ is the electrolyser stack thermal capacity in W/K, T_{ELY} is the electrolyser temperature in K, $\dot{Q}_{ez}^{(G)}$ is the generated heat during the electrolysis (in W), $\dot{Q}_{ez}^{(C)}$ is the cooling thermal power expressed in W, and $\dot{Q}_{ez}^{(L)}$ represents the heat losses (in W).

2.6. Simulation and Validation of the Alkaline Electrolyser

The dynamic model of the electrolyser has been implemented in Simulink. The unique input of the dynamic model is the power requested in kW, while the outputs are the temperature in °C, the stack voltage and current (in V and A, respectively), the hydrogen produced in lpm and the performance in %. The main parameters of the computation model are shown in Table 3.

Table 3. Alkaline electrolyser. Parameters of the dynamic model.

Parameter	Value	Unit
s	0.35	V
t	0.11	$A\ m^{-2}$
r	0.011	$\Omega\ m^2$
$C_{th,ELY}$	4184	$J\ K^{-1}$

The model is validated using laboratory measurements on a 8 kW alkaline electrolyser. The input power has been raised up to about 8 kW within a step. Then, the electrolyser is operated at the nominal power for 4 min (Figure 4).




Figure 4. Alkaline electrolyser validation. Input: (a) active power in W. Outputs: (b) stack voltage in V; maximum error at steady state of 4.58%. (c) stack current in A; maximum error at steady state of 6.48%. (d) stack temperature in °C; maximum error at steady state of 2.13%. (e) flow rate in lpm; maximum error at steady state of 1.89%. (f) I - U characteristic curve at 35 °C

In Figure 4, the active power corresponds to the overall power of the system. i.e., power requested by the electrolyser and losses which are estimated as 400 W. The stack voltage and stack current of the validating model steadies at 44.02 V and 126 A with errors of 4.58%

and 6.45% respectively. The temperature reaches its steady state to 30.65 °C after 150 s with an error of 2.13% and hydrogen production steadies at 19.91 lpm with an error of 1.89 %. Furthermore, the characteristic curve of the electrolyser at 35 °C is presented. While the open circuit voltage of the ELY cell is 1.229 V, the output voltage when the electrolyser provides 50 A is 4.5 V. The results show that the model is quite accurate and may be used to predict the output variables of the electrolyser.

2.7. PEM Fuel Cell

The PEM FC produces electricity by combining hydrogen (i.e., the fuel) and the oxygen (i.e., the oxidant). Reaction byproducts are heat and water [26,29]. The FC stack is composed of a number of cells connected in series, to have high output voltage and power. The modules obtained are able to offer as outputs powers lying in the range between 100 W to thousands kW, reaching average efficiencies between 40% and 60%. The FC modelled in the H_μG is composed by one stack of 110 cells and provides a rated power of 12.5 kW. The PEM fuel cell is equipped to guarantee the self-humidification and get from the air the required oxygen. The fuel cell technical specifications are summarized Table 4.

Table 4. Technical specifications of the PEM fuel cell.

Technical Parameter	Value	Unit
Rated power	12.5	kW
Nominal voltage	83.7	V
Nominal current	150	A
H ₂ consumption at rated power	178	lpm
Membrane thickness	178	μm
Nominal air fuel rate	250	lpm
Humidity	14	-
Cell number	110	-
E ₀ potential	1.229	V

The architecture of the model is equivalent to the structure of the alkaline electrolyser (presented before, in Figure 3), shown for the PEM fuel cell in Figure 5. In the model, the following assumptions are considered [29]:

1. There is a prevalent dimension, i.e., the spatial distribution can be considered one-dimensional
2. The gases follow the ideal gas law and are distributed in uniform way
3. It is considered a negligible pressure variation in the FC gas flow channels
4. Both the fuel (hydrogen) and the oxidant (air) are humidified
5. Thermodynamic properties refer to the mean temperature.
6. It is considered a negligible stack temperature variation
7. It is supposed a constant stack heat capacity




Figure 5. Block diagram of sub-models for a PEM fuel cell.

The presented model is based on three sub-models, which can be run separately, but are linked to each other. The sub-models are the electrical sub-model, the thermal sub-model and the hydrogen consumption sub-model.

2.7.1. Electrical Sub-Model

As for the alkaline electrolyser, the PEM fuel cell model is based on a number of relationships, covering thermodynamics and heat transfer aspects [27][32]. The operating cell voltage is expressed by Equation (13) :

$$U_{FC} = U_{OC} - U_a - U_{ohm} - U_c \quad (13)$$

where U_{OC} is the open circuit voltage, U_a indicates the activation overvoltage, U_{ohm} refers to the ohmic overvoltage, and U_c is the overvoltage term referring to the reactant concentration. All terms are measured in V.

2.7.2. Thermal Sub-Model

The fuel cell thermal sub-model is determined on the basis of a lumped thermal model. The heat generated during the fuel cell use is expressed through Equation (14):

$$C_{th,FC} \frac{dT_{FC}}{dt} = \dot{Q}_{H_{reac}} - W_{elec} - \dot{Q}_a \quad (14)$$

where $\dot{Q}_{H_{reac}}$ indicated the enthalpy related to the water formation, W_{elec} is the energy incorporated produced as electricity, and \dot{Q}_a is heat dissipated through convection and the one removed through the cooling system.

2.7.3. Fuel Consumption Sub-Model

The required fuel (i.e., hydrogen) is obtained through Equation (15).

$$\dot{m}_{fc} = \frac{N_{cells} \cdot I_{fc}}{z \cdot F} \quad (15)$$

where \dot{m}_{fc} indicated the hydrogen flow expressed in mol/s, N_{cells} is FC cell number, I_{fc} indicated the stack current (in A), z number of molecule's electrons, and F is the Faraday constant in C/mol.

2.8. Simulation and Validation of the PEM FC

The dynamic model of the PEM FC has been implemented in Matlab Simulink[®]. The inputs of the model are the hydrogen requested in lpm and the nominal FC current in A, while the outputs are the produced power in kW, the FC voltage in V, the actual FC current in A and the hydrogen consumption in lpm.

The model is validated using laboratory measurements on a 12.5 kW PEM fuel cell stack composed by 110 cells (see Figure 6). Measured data correspond to the following conditions: 40% of oxidant composition O_2 , air pressure at 1 bar and variable load. During the validation tests the H_2 consumption increases from 100 to 200 lpm, whereas the air flow rate is almost constant at 200 lpm. The maximum error obtained on the current is 0.1%, on the voltage 8.7% and on the power 7.5%.




Figure 6. PEM fuel cell validation at 40% of oxidant composition O_2 and 1 bar of air pressure. Inputs; (a) H_2 flow rate in lpm and (b) air flow rate in lpm. Outputs: (c) stack power in W with maximum error of 7.5%, (d) stack voltage in V with maximum error of 8.7% and (e) stack current in A with maximum error of 0.1%, (f) I - U characteristic curve.

2.9. Hydrogen Storage Tank

The storage of the hydrogen can be done under different forms, i.e., as gas, liquid or with an intermediate means. In the modelled H_2 G the produced hydrogen stored in a high pressure tank [33]. The tank capacity is imposed equal to 9 m^3 . The tank specifications are summarized in Table 5.

Table 5. Technical specifications of the hydrogen storage tank.

Characteristic	Value	Unit
Storage capacity	9	m^3
Maximum level	10	%
Minimum level	95	%

2.10. Hydrogen Tank Modelling

The hydrogen tank modelling approach is shown in Equation (16).

$$\dot{m}_{tk} = \dot{m}_{ELY} - \dot{m}_{FC} - \dot{m}_{leak} \quad (16)$$

where \dot{m}_{tk} is the hydrogen storage rate of the tank, \dot{m}_{ELY} is the rate of hydrogen production, \dot{m}_{FC} represents the hydrogen flow withdrawn by the PEM FC, and \dot{m}_{leak} refers to the hydrogen leakages, all terms in m^3/s . Despising the leakage, Equation (16) can be written again as Equation (17).

$$m_{tk} = m_o + \int (\dot{m}_{ELY} - \dot{m}_{FC}) \cdot dt \quad (17)$$

where m_{tk} and m_o are the stored hydrogen and the initial condition of the tank, respectively (both in m^3). Assuming ideal gas conditions, the pressure inside the tank can be obtained as Equation (18):

$$p_{tk} = \frac{n_{tk} \cdot R \cdot T_{tk}}{V_{tk}} \quad (18)$$

where p_{tk} is the pressure in the tank, n_{tk} indicates the stored moles of hydrogen in the tank, R is the ideal gas constant, T_{tk} refers to the stored hydrogen temperature, and V_{tk} indicates the tank volume.

2.11. Simulating and Validating Hydrogen Storage Tank

The inputs of the model are the hydrogen production by the electrolyser in lpm and the hydrogen consumption by the PEM fuel cell in lpm. The output is the tank level expressed in % or m^3 . The hydrogen tank has a capacity of $9 m^3$. The model is validated with a constant flow rate of 20 lpm. It is required supplying 7.5 h with a constant inlet flow of 20 lpm of hydrogen to charge the tank from its minimum capacity ($0 m^3$) until its maximum capacity ($9 m^3$), see Figure 7.




Figure 7. Hydrogen storage tank model. Charging - discharging hydrogen tank with a constant flow rate of 20 lpm.

3. Control Strategy

This section shows the implemented control strategy for the H μ G, receiving the state variables as inputs and providing as outputs the control signals. In the following, the conditions to enable/disable the single models and the control signals are described. The initialization of the state variables into the Central Control System (CCS) is required to avoid algebraic loops. The supervisory control of the CCS is presented in Figure 8.




Figure 8. Central control system. Flow chart of model proposed. P_{PV} : PV power, P_{WD} : Wind power, $P_{WD}^{(cut-in)}$: Wind power at cut-in velocity, $P_{WD}^{(cut-out)}$: Wind power at cut-out velocity, P_{RES} : RES power, P_{LOAD} : Load power, $P_{PEM}^{(min)}$: Minimum power electrolyser, $P_{PEM}^{(min)}$: Minimum power fuel cell and $P_{ELY}^{(Rated power)}$: Electrolyser rated power.

In the CCS all individual models are combined, and the connection among them is made by sending and receiving the system state variable. Table 6 summarizes the inputs and outputs of the model.

Table 6. Inputs and outputs of CCS.

System	Input	Unit	Outputs
PV	Active power	kW	PV enable signal
PV	Active solar irradiance	W/m ²	-
WD	Active power	kW	WT enable signal
WD	Wind speed	kW	-
Load	Power demand	kW	-
PEM FC	Power produced	kW	PEM FC enable signal
ELY	Power requested	kW	ELY enable signal
HST	Tank level	%	Charging subsystem enable signal
HST	-	-	Discharging subsystem enable signal

The models related to RES are connected to the grid at the point of common coupling (PCC) and activated according to environmental conditions, i.e., wind speed or presence of clouds. Furthermore, an activation hysteresis has been considered to avoid an intermittent operation of the systems due to sudden changes of the environmental conditions. These models might be disconnected through an enabling signal which switches to 0 the output, i.e., the active power. On the one hand, when the wind speed is lying between 5 m/s and 30 m/s for at least 500 s, the WD turbine may inject active power into the grid or supply the alkaline electrolyser. On the other hand, when the solar irradiance is higher than 100 W/m² for a 500s-period, the PV system may inject active power either to the local demand or to the electrolyser.

With reference to the electrolyser, it is switched *on* when the following conditions are satisfied: (i) the sum of the power produced by the wind turbine P_{WD} and photovoltaic system P_{PV} is higher, for a period of 500 s, than the sum of the load power P_{LOAD} and the minimum operating power of the electrolyser $P_{ELY}^{(min)}$; (ii) the level of hydrogen tank lies between its minimum and maximum capacity. These two conditions are shown in Equations (19) and (20).

$$P_{PV} + P_{WD} \geq P_{LOAD} + P_{ELY}^{(min)} \quad (19)$$

$$HST_{Level}^{(min)} < HST_{Level} < HST_{Level}^{(max)} \quad (20)$$

Once the electrolyser is *on*, the PEM fuel cell is automatically blocked (i.e., switched *off*).

When instead the condition shown in Equation (21) (which should be valid for a 500s-period) Equations (22) and (23) are satisfied, the electrolyser is turn *off*.

$$P_{PV} + P_{WD} < P_{LOAD} + P_{ELY}^{(min*)} \quad (21)$$

$$HST_{Level} > HST_{Level}^{(max)} \quad (22)$$

$$HST_{Level} < HST_{Level}^{(min)} \quad (23)$$

being $P_{ELY}^{(min)}$ and $P_{ELY}^{(min*)}$ the 20 % and 15 % of the electrolyser rated power, respectively.

By considering the operation of the PEM fuel cell, it is switched *on* when the following conditions exist: (i) the tank level respects the condition (20), (ii) the sum of P_{WT} and P_{PV} is lower than P_{LOAD} for a period of 500 s (as shown in Equation (24)), (iii) the load demand is higher than the minimum operating power of the PEM fuel cell (i.e., $P_{PEM}^{(min*)}$), as reported in Equation (25).

$$P_{PV} + P_{WD} < P_{LOAD} \quad (24)$$

$$P_{PEM}^{(min)} < P_{LOAD} \quad (25)$$

when the PEM fuel cell is switched *on* the electrolyser is automatically turned *off*.

The PEM fuel cell is switched *off* when the following conditions are met: (i) the tank level is lower than its minimum level (as Equation (23)), (ii) the sum of P_{WT} and P_{PV} is higher than P_{LOAD} , for a period of 500s (as reported in Equation (26)), (ii) the load demand is lower than the PEM minimum operating power $P_{PEM}^{(min)}$, as shown in Equation (27).

$$P_{PV} + P_{WD} > P_{LOAD} \quad (26)$$

$$P_{PEM}^{(min*)} > P_{LOAD} \quad (27)$$

The values of $P_{PEM}^{(min)}$ and $P_{PEM}^{(min*)}$ are chosen to be 20 % and 15 % of the PEM fuel cell rated power, respectively.

Finally, the last component of the H μ G is the hydrogen tank. It may operate between 10 % and 95 % of its capacity. As mentioned before, its level allows controlling the operation of electrolyser and PEM fuel cell: when the tank level reaches its maximum value, the electrolyser (if in operation) is turned *off*. Conversely, when the tank level reaches its minimum value, the PEM, if in operation, is turned *off*. The tank model has two enabling signals, i.e., the first one allows to activate the charging of the tank, while the second one activates the discharging.

4. Simulation Results

This section shows the simulation results of the H μ G operation. In Section 4.1 the integration of the modules into the whole system is shown. Moreover, the performance of the entire system are checked with simple inputs, to verify the correctness of the system response. Then, the test load profile is substituted with a real load profile, and the results are shown in Section 4.2.

4.1. Integration of the H μ G Modules and Preliminary Tests

The global model of the H μ G is shown in Figure 9. The model is composed of eight sub-models. The first sub-model is the CCS: it receives information simultaneously from six subsystems, i.e., (i) WD turbine, (ii) PV system, (iii) load, (iv) grid, (v) HST and (vi) PEM fuel cell. In the meanwhile, it sends command signals to the (vii) electrolyser subsystem.




Figure 9. Global model. Integration of single models to central control system.

Since the hydrogen-subsystems are supposed to be part of the microgrid, the RES sources are connected to the medium voltage level utility grid at the PCC, whose power balance is represented by Equation (1), which can be rewritten as in (28):

$$P_{GRID} = P_{LOAD} - P_{GEN} + P_{ELY} = P_{LOAD} - (P_{PV} + P_{WT} + P_{PEM}) + P_{ELY} \quad (28)$$

1. $P_{GRID} = 0$: Absolute equilibrium between the load demand, the power produced by the RES and the contribution of the hydrogen system.
2. $P_{GRID} > 0$: Independently of the contribution of the hydrogen system and the RES, the grid is necessary for meeting the demand.
3. $P_{GRID} < 0$: The H μ G is injecting power into the grid.

The global model has been tested by using test profiles, for both RES and load demand. The simulations are performed under variable wind speed and solar irradiance conditions, considering different scenarios. This was done in order to demonstrate that the operation of the whole hydrogen system provides the expected results. Two scenarios have been considered: the **Scenario 1** considers a favorable RES production, whereas the **Scenario 2** considers a scarce RES generation. It is expected a role for the alkaline electrolyser in **Scenario 1**, whereas in **Scenario 2**, the operation of the PEM fuel cell should be predominant.

The validation profiles are shown in Figure 10. In particular, Figure 10a shows a characteristic residential load, composed of two peaks over 24 h, i.e., 20 kW at 8 h and 18 kW at 17 h. The energy demand during the day is 245.03 kWh and the time stamp of the validation profile is 40 min.




Figure 10. Load profile; (a) active power in kW. PV system; Inputs: (b) solar irradiance in W/m^2 and (c) temperature in $^{\circ}C$. Output: (d) active power in kW. WD system; Input: (e) Wind speed in m/s. Output: (f) Active power in kW.

Hourly data of solar irradiance on the horizontal plane and temperature are the inputs of the PV system, whereas the unique output of the PV system is the active power produced (see Figure 10.b–d). The energy produced during the day is 126.27 kWh and the profiles of solar irradiance and temperature have been chosen strategically in order to get about the 50% of the load demand from the PV system.

The wind turbine model has one input (wind speed) and one output (produced active power). As for the PV system, the WD turbine system produces 126.80 kWh contributing with the another 50% to the load demand. The input and the output of the WD turbine model are presented in Figure 10.e–f.

4.1.1. Effect of the Presence of the Hydrogen-Based System

First of all, the impact of the presence of the hydrogen-based system (i.e., electrolyser, fuel cell and tank) on the PCC is analysed and the results are summarised in Figure 11. When the hydrogen-based system is not installed, during the first 5 h the contribution of the grid to the energy balance is small due to the presence of the RES. Later in the day, the power produced by the PV system reaches its peak and this leads to an injection of power into the grid. Then, in the last part of the day (night hours), due to the absence of solar irradiance, the grid provides an amount of power almost equal to the power demand.





Figure 11. Integrated-System Simulation. Confronting performance of the system with/without hydrogen-based system. Active power exchange with the grid in kW.


On the other hand, when the hydrogen-based system is installed, we can note a constant reduction of the power exchanged with the grid when the electrolyser is in operation (i.e., from 0 h until 16 h). During the first 6 h, the value of the energy generated from RES is low and the electrolyser works at its minimum power. Then, during the earlier hours, the response of the system with and without hydrogen-based system are almost the same.

4.1.2. H₂G Response with the Test Profiles


The performance of the H₂G when the profiles shown in Figure 10 are used and the Scenario-1 (i.e., high RES production) is considered are summarised in Figure 12. In Figure 12.a, the load demand and active power exchanged with the grid are reported: it is evident that the grid is used as buffer, because the sign of the power exchanged varies along the time. The information on load and grid power, together with the RES profiles (reported in Figure 12.b), allows understanding the behavior of the hydrogen-based system. As shown in Figure 12.c–d), during the first 8 h, the electrolyser works at its minimum power (10% of its rated capacity, i.e., 0.8 kW) and charges the hydrogen storage tank (as shown in Figure 12.e). Then, the electrolyser operates at its rated power (i.e., 8 kW) due to the increase of RES during the midday hours. After 14 h, the hydrogen storage tank reaches its maximum level (i.e., 95% of its capacity) and the electrolyser is turned off. The energy requested by the electrolyser during the day is 60.19 kWh. When the electrolyser operates at its rated power, the electrical values are: nominal voltage 44.02 V and nominal current 126 A.




(a) Load and grid active power




(b) PV and wind production



(c) ELY consumption and PEM production



(d) ELY and PEM flow rate



(e) Tank level

Figure 12. Global model of $H\mu G$. Response to validation load profile. Power balance at PCC with active power in kW.

In Figure 12.d we can note a constant H_2 flow towards the storage tank equal to 20.03 lpm. The operating temperature for the device is 30 °C.

For the PEM fuel cell, we can note in Figure 12.c that it works during 1.5 h out 24 h, and during this time it consumes the H_2 available into the hydrogen storage tank until it reaches the minimum level (10 % of its capacity). During this relatively short period, the PEM fuel cell delivers 6.66 kWh. The voltage of the PEM fuel cell is almost constant and is about 80 V, while the current varies as function of the power requested to reach the demand. In Figure 12.d is presented the PEM H_2 flow rate in lpm, reaching up to 150 lpm.

Finally, in Figure 12.e is shown the tank level in m^3 and in %. If the tank is charging, the tank level might increase until it reaches the 95 % of its capacity ($6.5 m^3$), whereas, when the tank is discharging, it decreases until the 10 % of its minimum capacity ($0.7 m^3$). The capacity of the tank has been chosen $7 m^3$ in the validation case, in order to charge until its maximum level ($6.5 m^3$) in 5.5 h with a constant inlet flow of hydrogen of 20 lpm.

It is worth noting that the operation of the alkaline electrolyser and the PEM fuel is not simultaneously: in other words, when the electrolyser is powered, the PEM fuel cell cannot produce active power and vice versa. Furthermore, with a surplus of power produced by WD and PV systems, it is allowed the injection of power into the grid only when the surplus is higher than the rated power of the electrolyser. Hence, the performance of the global model is as it was expected. In particular, at midday (between 9 h and 14 h), the power generated from the PV system plays an important role and the electrolyser tends to work at its rated power. Then, in this period the level of the hydrogen storage tank reaches its maximum capacity. After, between 14 h and 17 h, with the presence of the hydrogen system, there is an equilibrium of the power flow ($P_{GRID} = 0$) due to the response of the PEM fuel cell: over this period, the demand is reached by the sum of the power generated from the RES and the PEM fuel cell. Finally, in the nights hours (after 18 h), the hydrogen storage decreases until its minimum capacity and the PEM fuel cell is turned off. Being during the night a poor production of power from the PV system, the electrolyser cannot be turned on, and, as a consequence, the load demand is met mainly thanks to the contribution of the grid. It is clear the contemporary presence of RES generation and load demand is fundamental for understanding the performance of the H μ G. Hence, the zoom of the subplots reported in Figure 12 (related to Scenario-1) between 12.5 h and 14.5 h and the curves related to the Scenario-2 in the same time range are shown in Figure 13a,b, respectively.




Figure 13. Global model performance of the $H\mu G$ in different scenarios using a validation load profile. **Scenario 1:** H_2 production; both favorable wind and solar irradiance conditions. **Scenario 2:** H_2 consumption; scarce wind speed and solar irradiance conditions.

For Scenario-1, as already mentioned, the electrolyser operates at rated power, while the PEM fuel cell is off and the tank is filled until its maximum level (95% of its capacity). Between 12.5 h and 14.5 h the amount of RES power generated is relatively high and there is an injection of power into the grid as well. Conversely, in the Scenario-2 the PEM fuel cell is in operation, while the electrolyser is off. Moreover, there is no power injected into the grid and the hydrogen tank tends to discharge constantly (due to the PEM consumption).

4.2. Performance of the $H\mu G$ with Measured Load Profile

4.2.1. Effect of the Presence of the Hydrogen-Based System

The performance of the $H\mu G$, with and without the hydrogen-based system, is reported in Figure 14. In the first 6 h, it is observed a small difference in the response in the two cases due to the operation of the electrolyser at its minimum power (0.8 kW) when the RES power is not high. In the midday hours (between 6 h and 16 h), the system is sensible to the presence of the hydrogen system and it is worth noting a high discrepancy between the responses of the two cases. The operation of the PEM fuel cell occurs between 16 h and 18 h: in this period, we can see an almost null contribution from the grid to meet power demand. Finally, after 19 h, the hydrogen tank is empty and the RES energy produced is not high enough to supply the electrolyser: hence, the behavior with and without the hydrogen-based system is similar.






Figure 14. Confronting performance of the system with/without hydrogen system under a static load profile. Active power exchange with the grid in kW.

4.2.2. H₂G Response with the Measured Load Profile


The power balance at the PCC is shown in Figure 15. We can see for the first 7 h a constant contribution of the grid, whereas a reverse power flow exists during the midday hours. In this case, the electrolyser produces hydrogen between 9 h and 16 h (midday hours when RES generation is high) and the PEM fuel cell works to meet the demand between 16 h and 18 h. Finally, during the latest hours, the contribution of the grid to meet the power demand is predominant. Overall, it is consumed the 23.79% (60.20 kWh) of the total energy obtained from the RES (253.08 kWh) to operate the electrolyser. Moreover, 12.66 kWh are provided by the PEM fuel cell to meet the power demand.




(a) Load and grid active power




(b) PV and wind production



(c) ELY consumption and PEM production



(d) ELY and PEM flow rate



(e) Tank level

Figure 15. Response of the H μ G under a real load profile. Power balance at PCC in kW.

4.2.3. Sensitivity Analysis

The performance of the H₂G with the real load profile is assessed through a sensitivity analysis presented in Table 7 based on the following cases:

1. One photovoltaic system, one wind turbine system and one electrolyser.
2. Two photovoltaic systems, two wind turbine systems and one electrolyser.
3. Two photovoltaic systems, two wind turbine systems and two electrolyses.

Table 7. Sensitivity analysis of hydrogen system performance with a real load profile.

PV	WT	ELY	HST m ²	PV kWh	WT kWh	ELY kWh	PEM kWh	Grid In-jection kWh
1	1	0	0	126.27	126.80	0.00	0.00	−8.04
1	1	1	12	126.27	126.80	60.20	12.13	40.04
1	1	1	15	126.27	126.80	60.20	11.60	40.57
1	1	1	27	126.27	126.80	60.34	9.69	42.61
1	1	1	54	126.27	126.80	60.34	5.07	47.24
2	2	0	0	252.54	253.60	0.00	0.00	−261.11
2	2	1	7	252.52	253.59	55.39	10.16	−215.84
2	2	1	9	252.52	253.59	65.63	13.42	−208.87
2	2	1	12	252.52	253.59	83.64	16.66	−194.10
2	2	1	15	252.52	253.59	101.67	20.89	−180.29
2	2	1	27	252.52	253.59	111.36	21.71	−171.43
2	2	1	54	252.52	253.59	111.36	17.26	−166.98
2	2	2	7	252.53	253.60	67.45	10.73	−204.38
2	2	2	9	252.53	253.60	75.91	13.44	−198.63
2	2	2	12	252.53	253.60	95.21	16.91	−182.79
2	2	2	15	252.53	253.60	113.23	21.13	−169.00
2	2	2	27	252.53	253.60	183.66	37.74	−115.18
2	2	2	54	252.53	253.60	212.86	40.66	−88.89

(i) wind speed average: 6.58 m/s. (ii) solar irradiance average: 249.11 W/m². (iii) temperature average: 30.38 °C. (iv) demand energy: 245.03 kWh.

In these three cases, the capability of the hydrogen tank is increased gradually, studying the response of the PEM fuel cell and the power balance at the PCC. Wind speed, solar irradiance and operating temperature of the photovoltaic system are common for all the cases. In the first case (one photovoltaic system, one wind turbine system and one electrolyser), the total energy produced by RES is 253.07 kWh, which is almost equal to the energy of the load (245.03 kWh). When the system operates without the hydrogen system, the grid contribution of the system is −8.04 kWh (i.e., there is an injection of power in the grid). Then, adding the hydrogen system and having constant from RES, if the capability of the hydrogen tank increases (from 12 m³ to 54 m³), the power returned from the PEM fuel cell decreases (from 12.13 kWh to 5.07 kWh) and the grid contribution becomes positive (passing from −8.04 kWh to 47.24 kWh).

The second case (two photovoltaic systems, two wind turbine systems and one electrolyser) doubles the contribution from the RES (506.15 kWh), but there is still only one electrolyser. When the capability of the hydrogen tank increases (from 7 m³ to 54 m³), the power given by the PEM fuel cell to the load increases (from 10.16 kWh to 21.71 kWh) and the grid contribution increases as well, i.e., the reverse power flow is reduced from −261.11 kWh to −166.98 kWh. Finally, in the last case (two photovoltaic systems, two wind turbine systems and two electrolyses), again the contribution from the RES is doubled and a second electrolyser is added. By increasing the capability of the hydrogen tank

(from 7 m³ to 54 m³), the power returned from the PEM fuel cell to the load increases (from 10.73 kWh to 40.66 kWh) and grid contribution increases (from −204.38 to −88.89 kWh).

The results obtained with the sensitivity analysis show the importance of the hydrogen tank capability for the contribution of the PEM fuel cell. The operation of the electrolyzer is directly proportional to the capability of the tank and the energy produced from the RES, whereas the operation of the PEM fuel cell depends on the dimension of the hydrogen tank. With a small tank, it is not possible to have a high value of power injected to the grid, independently by the RES production.

5. Conclusions

This work presented a methodology to simulate the behavior of a Hybrid Microgrid, i.e., a Wind-Solar-Hydrogen Energy System. The system can produce hydrogen from the generation surplus and can use the produced hydrogen, stored in a tank, as energy carrier to be used later by a fuel cell for electricity generation. Mathematical models to simulate the dynamic behaviour of every system component (i.e., photovoltaic system, wind generator, alkaline electrolyser, PEM fuel cell and hydrogen tank) have been developed. The models encompass both dynamics and low computational requirements. The validation of electrolyser and PEM fuel cell models are presented as well. The outputs confirmed that both models may successfully depict the validation data. Results in validation process indicated an average error less than 2% for hydrogen production by electrolyzer and 6% for the power produced by PEM fuel cell. Furthermore, a supervisory control strategy for the Wind-Solar-Hydrogen system has been introduced as well.

The dynamic behavior of the Wind-Solar-Hydrogen system model has been shown by performing simulations in different wind velocity and solar irradiance conditions by considering a real load profile. The simulation results have shown a satisfactory operation, in which wind turbine, photovoltaic system and hydrogen-system are compensating each other, even if the complete self-sufficiency cannot be reached.

A sensitivity analysis has been also reported: it highlighted how the decoupling between the energy and power is positive to exploit the potential of the hydrogen system. In this way, the importance of the capability of the storage tank has been demonstrated for hydrogen systems integrated with RES.

In summary, the models of the different components developed in this paper were able to jointly operate under the supervision of the control logic, that was appositely designed to improve the self-sufficiency of the Hybrid Microgrid. The overall system has also proven to be a reliable tool for the performance evaluation of Wind-Solar-Hydrogen plants. Even though the developed model does not refer to any existing system, it allows to size the components of the hybrid microgrid at the design stage, by considering the real dynamics of both loads (electrolyser and passive load) and generation (fuel cell and renewable energy sources). Furthermore, it is possible to evaluate the overall system efficiency when the tank size is varied, as well as the self-sufficiency and the self-consumption of the system. This demonstration project can prepare the way for a future hydrogen marketplace and it will help researches to run scenario analysis, verify theoretical findings and optimize system operations. It is therefore expected that this work will help improving cost competitiveness of renewable energy and reduce market barriers for new energy and technology solutions in general, and hydrogen technology in particular. We trust that it is possible to supply remote areas with wind and solar power using hydrogen as storage medium, even if there are several aspects to improve in order to make the system competitive with respect to alternative systems (like wind-diesel).

Author Contributions: Conceptualization, A.M. and E.P.; methodology, A.M., E.P., J.E.V.L.; software, J.V.; validation, J.E.V.L., H.L.; data curation, A.M., E.P., H.L.; writing—original draft preparation, J.E.V.L.; writing—review and editing, A.M. and E.P.; supervision, E.B. All authors have read and agreed to the published version of the manuscript.

Funding: This research was partially funded by European Union's Horizon 2020 research and innovation programme under grant agreement No. 691797 (project STORE&GO). The paper only reflects the authors' views and the European Union is not liable for any use that may be made of the information contained herein.

Acknowledgments: The Authors would like to acknowledge the valuable support provided by Massimo Santarelli (Politecnico di Torino) and Sabina Fiorot (EnviPark - Torino).

Conflicts of Interest: The authors declare no conflict of interest

Abbreviations

The following abbreviations are used in this manuscript:

CCS	Central Contro System
DG	Distributed Generation
ELY	Electrolyser
ESS	Energy Storage System
FC	Fuel Cell
FCH JU	Fuel Cells and Hydrogen Joint Undertaking
H _μ G	Hybrid Microgrid
HST	Hydrogen Storage Tank
P2F	Power-to-Fuel
P2G	Power-to-Gas
P2H	Power-to-Heat
PEM	Proton Exchange Membrane
PCC	Point of Common Coupling
PV	Photovoltaic
SoC	State of Charge
VRES	Variable Renewable Energy Sources
WD	Wind

References

1. Zhou, T.; Francois, B. *Modeling and Control Design of Hydrogen Production Process for an Active Hydrogen/Wind Hybrid Power System*; Ecole Centrale de Lille, Cite Scientifique: Villeneuve d'Ascq, France, 2008.
2. Spertino, F.; Ahmad, J.; Chicco, G.; Ciocia, A.; Leo, P.D. Matching between Electric Generation and Load: Hybrid PV-Wind System and Tertiary-Sector Users. In Proceedings of the UPEC 2015, Stoke-on-Trent, UK, 1–4 September 2015.
3. Diaz-Londono, C.; Eneacu, D.; Ruiz, F.; Mazza, A. Experimental modeling and aggregation strategy for thermoelectric refrigeration units as flexible loads. *Appl. Energy* **2020**, *272*, 115065.
4. Enescu, D.; Ciocia, A.; Mazza, A.; Russo, A. Solutions based on thermoelectric refrigerators in humanitarian contexts. *Sustain. Energy Technol. Assess.* **2017**, *22*, 134–149.
5. Tindemans, S.H.; Trovato, V.; Strbac, G. Decentralized control of thermostatic loads for flexible demand response. *IEEE Transact. Control Syst. Technol.* **2015**, *23*, 1685–1700.
6. Chicco, G.; Riaz, S.; Mazza, A.; Chicco, G. Flexibility from Distributed Multienergy Systems. *Proc. IEEE* **2020**, *108*, 1496–1517.
7. Sternberg, A.; Bardow, A. Power-to-What?—Environmental assessment of energy storage systems. *Energy Environ. Sci.* **2015**, *8*, 389–400.
8. Mazloomi, K.; Gomes, C. Hydrogen as an energy carrier: Prospects and challenges. *Renew. Sustain. Energy Rev.* **2012**, *16*, 3024–3033.
9. European Commission. European Green Deal. 2019. Available online: https://ec.europa.eu/info/strategy/priorities-2019-2024/european-green-deal_en (accessed on 22 February 2021).
10. European Commission. EU Hydrogen Strategy. 2020. Available online: https://ec.europa.eu/energy/sites/ener/files/hydrogen_strategy.pdf (accessed on 22 February 2021).
11. European Commission. A Clean Planet for All. A European strategic long-term vision for a prosperous, modern, competitive and climate neutral economy. 2018. Available online: https://ec.europa.eu/energy/sites/ener/files/documents/european_commission_-_a_european_strategic_long_term_vision_for_a_prosperous_modern_competitive_and_climate_neutral_economy.pdf (accessed on 22 February 2021).
12. China Industry-University-Research Institute Collaboration Association. Standard and Evaluation of Low-Carbon Hydrogen, Clean Hydrogen and Renewable Hydrogen. Available online: http://www.fuelcellchina.com/cnt_143.html (accessed on 29 December 2020).
13. Nastasi, B. Hydrogen policy, market and R&D project. In *Solar Hydrogen Production*, Calise, F., D'Accadia, M.D., Santerelli, M., Lanzini, A., Ferrero, D., Eds.; Cambridge, MA, USA: 2019.
14. Saury, F.; Tomlison, C. *Hybrid Microgrids: The Time is Now*; Caterpillar Inc.: Houston, Texas 2016.
15. Chandak, S.; Bhowmik, P.; Mishra, M. Autonomous Microgrid Operation Subsequent to an Anti-Islanding Scheme. *Sustainable Cities and Society*. **2018**, *39*, 430–448.
16. Okundamiya, M.S. Size optimization of a hybrid photovoltaic/fuel cell grid connected power system including hydrogen storage. *Int. J. Hydro. Energy* (In press).
17. Puranen, P.; Kosonen, A.; Ahola, J. Technical feasibility evaluation of a solar PV based off-grid domestic energy system with battery and hydrogen energy storage in northern climates. *Solar Energy* **2021**, *213*, 246–259.
18. Mohseni, S.; Brent, A.C.; Burmester, D. A comparison of metaheuristics for the optimal capacity planning of an isolated, battery-less, hydrogen-based micro-grid. *Appl. Energy* **2019**, *259*, 114224.
19. Cau, G.; Cocco, D.; Petrollese, M. Modeling and simulation of an isolated hybrid micro-grid with hydrogen production and storage. In Proceedings of the ATI2013, Bologna, Italy, 11–13 September 2013.
20. Li, L.; Chen, W.; Han, Y.; Li, Q.; Pu, Y. A Stability Enhancement Method Based on Adaptive Virtual Resistor for Electric-hydrogen Hybrid DC Microgrid Grid-connected Inverter Under Weak Grid. *Electric Power Syst. Res.* **2021**, *191*, 106882.
21. Valverde, L.; Rosa, F.; Bordons, C. Design, Planning and Management of a Hydrogen-Based Microgrid. *IEEE Transact. Ind. Inf.* **2013**, *9*, 1398–1404.
22. Petrollese, M.; Valverde, L.; Cocco, D.; Cau, G.; Guerra, J. Real-time integration of optimal generation scheduling with MPC for the energy management of a renewable hydrogen-based microgrid. *Appl. Energy* **2016**, *166*, 96–106.
23. Mazza, A.; Estebasari, A.; Morandi, G.; Bompard, E.; Lok, H. Remote Hardware-In-the-Loop Measurement System for Electrolyser Characterization. In proceedings of the IEEEIC 2019, Genova, Italy, 11–14 June 2019.
24. Lee, D.; Wang, L. Small-Signal Stability Analysis of an Autonomous Hybrid Renewable Energy Power Generation/Energy Storage System Part I: Time-Domain Simulations. *IEEE Transact. Energy Conv.* **2008**, *23*, 1.
25. Senjyu, T.; Uezato, K.; Funabashi, T. A Hybrid Power System Using Alternative Energy Facilities in Isolated Island. *IEEE Transact. Energy Conv.* **2005**, *20*, 2.
26. Gonzatti, F.; Farret, F.A. Mathematical and experimental basis to model energy storage systems composed of electrolyser, metal hydrides and fuel cells. *Energy Conv. Manag.* **2017**, *132*, 241–250.
27. Ulleberg, O. Modeling of advanced alkaline electrolyzers: A system simulation approach. *Int. J. Hydro. Energy* **2003**, *28*, 21–33.
28. Calise, F.; Figaj, R.D.; Massarotti, N.; Mauro, A.; Vanoli, L. Polygeneration system based on PEMFC, CPVT and electrolyser: Dynamic simulation and energetic and economic analysis. *Appl. Energy* **2017**, *192*, 530–542.
29. Valverde-Isorna, L.; Ali, D.; Hogg, D.; Abdel-Wahab, M. Modelling the performance of wind-hydrogen energy systems: Case study the Hydrogen Office in Scotland/UK. *Renew. Sustain. Energy Rev.* **2016**, *53*, 1313–1332.

-
30. Khalilnejad, A.; Sundararajan, A.; Abbaspour, A.; Sarwat, A. Optimal Operation of Combined Photovoltaic electrolyser Systems. *Energies* **2016**, *9*, 332.
 31. Pino, F.J.; Valverde, L.; Rosa, F. Influence of wind turbine power curve and electrolyser operating temperature on hydrogen production in wind-hydrogen systems. *J. Power Sources* **2011**, *196*, 4418–4426.
 32. Martin, I.S.; Ursua, A.; Sanchis, P. Modeling of PEM Fuel Cell Performance: Steady-State and Dynamic Experimental Validation. *Energies* **2014**, *7*, 670–700.
 33. Yigit, T.; Selamet, O.F. Mathematical modeling and dynamic Simulink simulation of high-pressure PEM electrolyser system. *Int. J. Hydr. Energy* **2016**, *41*, 13901–13914.